

Table 1 -- Public Notices Distributed Between March 1, 2018 and March 1, 2021

PWSID	SYSTEM NAME	DIVISION	TYPE OF NOTICE	DATE OF PUBLIC NOTICE	RESOLUTION
PA1460073	Main System	Southeast	Tier 1 BWN for approximately 100 customers due to a water main break.	1/2/2018	The water main was fixed and service restored. After satisfactory microbiological results, the boil water order was lifted on 1/5/2018.
PA1460073	Main System	Southeast	Tier 1 BWN for approximately 18 customers due to a water main break.	3/2/2018	The water main was fixed and service restored. After satisfactory microbiological results, the boil water order was lifted on 3/5/2018.
PA1090078	Bensalem Water System	Southeast	Tier 1 BWN for a section of the system due to a water main break.	12/27/2018	The water main was fixed and service restored. After satisfactory microbiological results, the boil water order was lifted on 12/30/2018.
PA1090078	Bensalem Water System	Southeast	Tier 3 PN for collecting 2017 DBP samples outside of the required 3 day sampling period. PN was included in customer bills.	6/1- 6/30/2018	Sampling procedure was updated to minimize this type of violation from occurring again.
PA2660018	Bunker Hill Water System	White Haven	Tier 3 PN for collecting 2018 DBP samples outside of the required 3 day sampling period. PN was included in customer bills.	5/1- 5/31/2019	Sampling procedure was updated to minimize this type of violation from occurring again.
PA2640017	Garden Hills	Honesdale	Tier 1 BWN due to loss of power which caused loss of positive pressure in a water distribution system.	3/5/2018	System power and pressure were restored. After satisfactory microbiological results, the boil water order was lifted on 3/8/2018.
PA1460028	Hatboro Water System	Southeast	Tier 3 PN for collecting 2017 DBP samples outside of the required 3 day sampling period. PN was included in customer bills.	5/1- 5/31/2018	Sampling procedure was updated to minimize this type of violation from occurring again.
PA2640018	Honesdale	Honesdale	Tier 1 BWN due to a water main freezing which caused loss of positive pressure in the distribution system.	1/7/2018	The water main was unfrozen and service restored. After satisfactory microbiological results, the boil water order was lifted on 1/11/2018.
PA2640048	Paupack Lake	Honesdale	Tier 1 BWN due to loss of power which caused loss of positive pressure in a water distribution system.	3/4/2018	System power and pressure were restored. After satisfactory microbiological results, the boil water order was lifted on 3/8/2018.
PA2641005	Pine Beach	Honesdale	Tier 1 BWN due to loss of power which caused loss of positive pressure in a water distribution system.	3/3/2018	System power and pressure were restored. After satisfactory microbiological results, the boil water order was lifted on 3/8/2018.
PA2520061	Tafton	Honesdale	Tier 1 BWN due to loss of power which caused loss of positive pressure in a water distribution system.	3/3/2018	System power and pressure were restored. After satisfactory microbiological results, the boil water order was lifted on 3/8/2018.
PA2520992	Woodmont	Honesdale	Tier 1 BWN due to loss of power which caused loss of positive pressure in a water distribution system.	3/4/2018	System power and pressure were restored. After satisfactory microbiological results, the boil water order was lifted on 3/8/2018.
PA2400114	Beech Mountain	White Haven	Tier 1 BWN as a result of efforts to rapidly refill the system before the next extended subfreezing weather period. Aqua used emergency pumps and pipes to fill the system's storage tank. These emergency facilities have been sanitized but the required bacteriological test results were not yet available before putting the emergency facilities into use.	1/16/2018	After satisfactory microbiological results, the boil water order was lifted on 1/21/2018.
PA2400114	Beech Mountain	White Haven	Tier 1 BWN as a result of significant rainfall causing groundwater to enter well.	7/26/2018	The clear well was flushed and cleaned. After satisfactory microbiological results, the boil water order was lifted on 7/29/2018.
PA2350037	Chinchilla I	White Haven	Tier 1 BWN due to a plumbing failure which resulted in a water outage for many customers of the Chinchilla I, Chinchilla II, and Stanton water systems.	6/5/2018	The plumbing issue was repaired. After satisfactory microbiological results, the boil water order was lifted on 6/7/2018.
PA2350036	Chinchilla II	White Haven	Tier 1 BWN due to a plumbing failure which resulted in a water outage for many customers of the Chinchilla I, Chinchilla II, and Stanton water systems.	6/5/2018	The plumbing issue was repaired. After satisfactory microbiological results, the boil water order was lifted on 6/7/2018.
PA2350004	Stanton	White Haven	Tier 1 BWN due to a plumbing failure which resulted in a water outage for many customers of the Chinchilla I, Chinchilla II, and Stanton water systems.	6/5/2018	The plumbing issue was repaired. After satisfactory microbiological results, the boil water order was lifted on 6/7/2018.
PA3540070	Eagle Rock	White Haven	Tier 1 BWN due to chlorine disinfection levels which dropped below the state required minimum level.	5/7/2018	The disinfection system issue has been corrected. After satisfactory microbiological results, the boil water order was lifted on 5/9/2018.

Table 1 -- Public Notices Distributed Between March 1, 2018 and March 1, 2021

[illegible]

Table 1 -- Public Notices Distributed Between March 1, 2018 and March 1, 2021

[illegible]